

Test result on A20-T25-S2-B-CR202-9-24VAC/DC

Testing ambient: room temperature (20°C)

Working voltage	Valve open/close time	Starting current	Standby current	Torque of open valve	Torque of close time
DC24V	4.41s	273mA	10mA	5.59N	4.76N
DC20V	4.11s	324mA	11mA	5.31N	4.91N
DC16V	4.36s	400mA	15mA	4.78N	5.06N
DC12V	4.57s	524mA	20mA	4.18N	5.28N
DC10V	4.80s	544mA	25mA	3.66N	5.26N
DC9V	5.12s	555mA	26mA	3.34N	5.27N
DC8V	6.14s	567mA	26mA	2.95N	4.51N
DC7V	7.91s	576mA	27mA	2.75N	4.97N